



**TYPICAL INSTALLATION
USING MAASS-MIDWEST
SANITARY WELL ACCESSORIES**

HEIGHT (PER CODE)

DEPTH
(BELOW FROST LINE)
(CHECK CODES)

PLASTIC PIPE. (THIS LINE IS
UNDER PRESSURE AT ALL TIMES).

DISTANCE (PER CODE)

LIST OF MATERIALS

- ① PITLESS ADAPTER, MAASS-MIDWEST or DICKEN SERIES.
- ② WATER TIGHT WELL CAP, MAASS-MIDWEST TYPE "WT" OR "WTC".
- ③ CHECK VALVE, MAASS-MIDWEST TYPE 529.
- ④ TORQUE ARRESTOR, MAASS-MIDWEST TYPE 5TA-48.
- ⑤ CABLE GUARD, MAASS-MIDWEST TYPE 90110. (ONE REQUIRED EVERY 10 FEET).
- ⑥ COUPLING, MAASS-MIDWEST TYPE 11BR (BRASS) OR TYPE 11P (PVC).
- ⑦ CHECK VALVE, MAASS-MIDWEST TYPE 530 or TYPE 531.
- ⑧ MAASS-MIDWEST HEAT SHRINK SPLICE KIT.
- ⑨ MAASS-MIDWEST RED BRASS INSERT FITTING.
- ⑩ STAINLESS STEEL PIPE CLAMPS, MAASS-MIDWEST 225 SERIES.
- ⑪ RED BRASS MALE ADAPTER, MAASS-MIDWEST TYPE "MA".
- ⑫ RED BRASS TANK TEE, MAASS-MIDWEST TYPE "TFB" or "TCB".
- ⑬ PRESSURE SWITCH, MAASS-MIDWEST TYPE "FSG".
- ⑭ MAASS-MIDWEST BRASS BOILER DRAIN VALVE.
- ⑮ MAASS-MIDWEST STEEL CASED PRESSURE GAUGE.
- ⑯ MAASS-MIDWEST BRASS GATE VALVE.

NOTE: Local codes and practices may vary. Check before installing the water system. This diagram is for general illustration purposes only. No warranties, expressed or implied, are conveyed regarding the accuracy or application of the information herein.